

SAN DIEGO COUNTY REGIONAL AIRPORT AUTHORITY

CODES

ARTICLE 8 - GENERAL OPERATIONS

PART 8.1 - AIRCRAFT

SECTION 8.12 - FIRES

(a) Smoking or lighting of open flames shall be prohibited in the following locations:

(1) Areas posted with “No Smoking” signs;

(2) On ramps or aprons; and

(3) Within 50 feet of hangars, fuel trucks or fuel loading stations.

(b) No person shall start an open fire any place on any facility or airport under the jurisdiction of the Authority without permission of the President/CEO.

(c) No person shall stock or store any material or equipment in such a manner as to constitute a fire hazard.

(d) Except for oil in sealed cans, no inflammable liquids or gases, including gasoline, dope, solvent and thinner, shall be stored in any hangar or building in quantities greater than one gallon; provided, however, separate buildings for such storage may be approved by the President/CEO.

(e) No person shall use a volatile inflammable substance for cleaning purposes inside any hangar or building.

(f) Tenants shall maintain hangar floors, gasoline pits and trucks clean and free of excess gasoline, grease and other inflammables.

(g) Tenants of all hangars and buildings shall provide suitable fire extinguishers and equipment in such condition as may be required by the Fire Marshall of the city in which the airport is located.

(h) Aircraft engines shall not be operated, nor shall aircraft electrical or radio equipment be operated in any hangar.

(i) The enactment of this section is not intended to preempt the public health regulations promulgated by the City of San Diego Municipal Code.

[Amended by Resolution No. 2019-0034 dated April 4, 2019.]

[Adopted by Resolution No. 2002-02 dated September 20, 2002.]